



**Send To: 3A240**

Mr. Matt Brown  
Bluescope Bartlett Liners Pty. Ltd.  
172 Ring Road Ballarat  
P.O. Box 49 Wendouree  
Victoria 3355  
Australia

**Facility: 3A241**

Bluescope Bartlett Liners Pty. Ltd.  
172 Ring Road Ballarat  
P.O. Box 49 Wendouree  
Victoria 3355  
Australia

Result	PASS	Report Date	23-MAY-2013
Customer Name	Bluescope Bartlett Liners Pty. Ltd.		
Tested To	NSF/ANSI 61		
Description	Aqualiner   Light green/black liner		
Trade Designation	Aqualiner		
Test Type	Annual Collection		
Job Number	A-00123126		
Project Number	9143889 (CLA, TE01)		
Project Manager	Susan Gauvin		

**Thank you for having your product tested by NSF International.**

Please contact your Project Manager if you have any questions or concerns pertaining to this report.

**Report Authorization**   
Amanda Phelka - Director, Toxicology Services

**Date** 23-MAY-2013



## General Information

Standard: NSF/ANSI 61

DCC Number: PM06287

Lot Number: 13A1214

Monitor Code: A

Physical Description of Sample: Light green/black liner

Trade Designation/Model Number: Aqualiner

Sample Id: **S-0000957707**  
 Description: Sample exposed at 23C and pH 5  
 Sampled Date: 04/27/2013  
 Received Date: 03/21/2013

### Normalization Information:

Date exposure completed:	27-APR-2013	Calculated N1:	0.11	Field Exposure Time:	24 hours	Lab Exposure Time	24 hours
Field Surface Area:	4.0 in <sup>2</sup>	Lab Surface Area:	139.83 in <sup>2</sup>	Calculated N2:	1.00	Calculated N4:	1.000
				Constant N2:	1	Misc. Factor:	1
Field Static Volume:	1 L	Lab Static Volume:	3.82 L				
				Calculated NFm:	1.00		
Compound Reference Key:	SPAC						

Testing Parameter	Sample	Control	Result	Normalized Result	Units
<b>Chemistry Lab</b>					
Aluminum in Drinking Water by ICPMS (Ref: EPA 200.8)					
Aluminum	ND(10)	ND(10)	ND(10)	ND(1)	ug/L
Total Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)					
Arsenic	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Barium in Drinking Water by ICPMS (Ref: EPA 200.8)					
Barium	3	3	ND(1)	ND(0.1)	ug/L
Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)					
Beryllium	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Bismuth in Drinking Water by ICPMS (Ref: EPA 200.8)					
Bismuth	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)					
Cadmium	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.02)	ug/L
Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)					
Chromium	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Copper in Drinking Water by ICPMS (Ref: EPA 200.8)					
Copper	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)					
Mercury	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.02)	ug/L
Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)					
Nickel	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Lead in Drinking Water by ICPMS (Ref: EPA 200.8)					
Lead	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)					
Antimony	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)					
Selenium	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L



Sample Id: **S-0000957707**

Testing Parameter	Sample	Control	Result	Normalized Result	Units
<b>Chemistry Lab ( Continued )</b>					
Tin in Drinking Water by ICPMS (Ref: EPA 200.8)					
Tin	12	14	ND(0.5)	ND(0.05)	ug/L
Strontium in Drinking Water by ICPMS (Ref: EPA 200.8)					
Strontium	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)					
Thallium	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.02)	ug/L
Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)					
Zinc	ND(10)	ND(10)	ND(10)	ND(1)	ug/L
Silver in Water by ICPMS (Ref: EPA 200.8)					
Silver	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L

Sample Id: **S-0000957708**

Description: Sample exposed at 23C and pH 10

Sampled Date: 04/27/2013

Received Date: 03/21/2013

Normalization Information:							
Date exposure completed:	27-APR-2013	Calculated N1:	0.11	Field Exposure Time:	24 hours	Lab Exposure Time	24 hours
Field Surface Area:	4.0 in2	Lab Surface Area:	139.83 in2	Calculated N2:	1.00	Calculated N4:	1.000
				Constant N2:	1	Misc. Factor:	1
Field Static Volume:	1 L	Lab Static Volume:	3.86 L				
				Calculated NFm:	1.00		
Compound Reference Key: SPAC							

Testing Parameter	Sample	Control	Result	Normalized Result	Units
<b>Chemistry Lab</b>					
Aluminum in Drinking Water by ICPMS (Ref: EPA 200.8)					
Aluminum	24	23	ND(10)	ND(1)	ug/L
Total Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)					
Arsenic	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Barium in Drinking Water by ICPMS (Ref: EPA 200.8)					
Barium	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)					
Beryllium	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.06)	ug/L
Bismuth in Drinking Water by ICPMS (Ref: EPA 200.8)					
Bismuth	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)					
Cadmium	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.02)	ug/L
Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)					
Chromium	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Copper in Drinking Water by ICPMS (Ref: EPA 200.8)					
Copper	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)					
Mercury	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.02)	ug/L
Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)					



Sample Id: **S-0000957708**

Testing Parameter	Sample	Control	Result	Normalized Result	Units
<b>Chemistry Lab ( Continued )</b>					
Nickel	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Lead in Drinking Water by ICPMS (Ref: EPA 200.8)					
Lead	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)					
Antimony	0.6	ND(0.5)	ND(0.5)	ND(0.06)	ug/L
Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)					
Selenium	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Tin in Drinking Water by ICPMS (Ref: EPA 200.8 )					
Tin	19	24	ND(0.5)	ND(0.06)	ug/L
Strontium in Drinking Water by ICPMS (Ref: EPA 200.8 )					
Strontium	1	1	ND(1)	ND(0.1)	ug/L
Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)					
Thallium	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.02)	ug/L
Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)					
Zinc	ND(10)	11	ND(10)	ND(1)	ug/L
Silver in Water by ICPMS (Ref: EPA 200.8)					
Silver	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L

Sample Id: **S-0000957709**

Description: Sample exposed at 23C and pH 8

Sampled Date: 04/27/2013

Received Date: 03/21/2013

<b>Normalization Information:</b>							
Date exposure completed:	27-APR-2013	Calculated N1:	0.11	Field Exposure Time:	24 hours	Lab Exposure Time	24 hours
Field Surface Area:	4.0 in2	Lab Surface Area:	139.83 in2	Calculated N2:	1.00	Calculated N4:	1.000
				Constant N2:	1	Misc. Factor:	1
Field Static Volume:	1 L	Lab Static Volume:	3.76 L				
				Calculated NFm:	1.00		
Compound Reference Key: SPAC							

Testing Parameter	Sample	Control	Result	Normalized Result	Units
<b>Chemistry Lab</b>					
BASE/NEUTRAL/ACID EPA METHOD 625 Scan for Tentatively Identified Compour					
No Compounds Detected	ND(4)	Complete	ND(4)	ND(0.4)	ug/L
Scan Control Complete	TRUE				
Semivolatile Compounds, Base/Neutral/Acid Target 625, Data Workup					
Pyridine	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Nitrosodimethylamine (N-)	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
N-Nitrosomethylethylamine	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
5-Methyl-2-hexanone (MIAK)	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
1-Methoxy-2-propanol acetate	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2-Heptanone	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Cyclohexanone	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L



Sample Id: S-0000957709

Testing Parameter	Sample	Control	Result	Normalized Result	Units
<b>Chemistry Lab ( Continued )</b>					
Nitrosodiethylamine (N-)	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Isobutylisobutyrate	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Aniline	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Phenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Di(chloroethyl) ether	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2-Chlorophenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2,3-Benzofuran	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
1,3-Dichlorobenzene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
1,4-Dichlorobenzene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
3-Cyclohexene-1-carbonitrile	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2-Ethylhexanol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Benzyl alcohol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
1,2-Dichlorobenzene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
bis(2-Chloroisopropyl)ether	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2-Methylphenol (o-Cresol)	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
N-Methylaniline	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Acetophenone	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
N-Nitrosodi-n-propylamine	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
N-Nitrosopyrrolidine	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
4-Methylphenol (p-Cresol)	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Hexachloroethane	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2-Phenyl-2-propanol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
N-Nitrosomorpholine	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Nitrobenzene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2,6-Dimethylphenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
N-Vinylpyrrolidinone	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
N-Nitrosopiperidine	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Triethylphosphate	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Isophorone	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2-Nitrophenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2,4-Dimethylphenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
bis(2-Chloroethoxy)methane	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2,4-Dichlorophenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Trichlorobenzene (1,2,4-)	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Naphthalene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
4-Chloroaniline	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
1,1,3,3,-Tetramethyl-2-thiourea	ND(4)	ND(4)	ND(4)	ND(0.4)	ug/L
Hexachlorobutadiene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Benzothiazole	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
N-Nitrosodi-n-butylamine	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
4-Chloro-3-methylphenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
p-tert-Butylphenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2-Ethylhexyl glycidyl ether	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2,6-Di-t-butyl-4-methylphenol(BHT)	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L



Sample Id: S-0000957709

Testing Parameter	Sample	Control	Result	Normalized Result	Units
<b>Chemistry Lab ( Continued )</b>					
Methylnaphthalene, 2-	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Benzyl alcohol, a,a-dimethyl-p-isopropyl-	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Cyclododecane	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2,4,5-Trichlorophenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2,4,6-trichlorophenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
1(3H)-Isobenzofuranone	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2-Chloronaphthalene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2-Nitroaniline	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
1,1'-(1,3-Phenylene)bis ethanone	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2,6-Di-tert-butylphenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Dimethylphthalate	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
1,1'-(1,4-Phenylene)bis ethanone	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Acenaphthylene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Benzenedimethanol, a,a,a',a'-tetramethyl-1,3-	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2,6-Dinitrotoluene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2,4-Dinitrotoluene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Benzenedimethanol, a,a,a',a'-Tetramethyl-1,4-	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
2,4-Di-tert-butylphenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Dimethyl terephthalate	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Acenaphthene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Dibenzofuran	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Ethyl-4-ethoxybenzoate	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
4-Nitrophenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Cyclododecanone	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Diethyl Phthalate	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
p-tert-Octylphenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Fluorene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
4-Chlorophenylphenylether	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
3-Nitroaniline	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
4-Nitroaniline	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Nitrosodiphenylamine (N-)	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Azobenzene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
4-Bromophenylphenylether	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Hexachlorobenzene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Pentachlorophenol	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Phenanthrene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Anthracene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Diisobutyl phthalate	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Dibutyl phthalate	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Hydroxymethylphenylbenzotriazole	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Fluoranthene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Pyrene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Butyl benzyl phthalate	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Di(2-ethylhexyl)adipate	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L



Sample Id: S-0000957709

Testing Parameter	Sample	Control	Result	Normalized Result	Units
<b>Chemistry Lab ( Continued )</b>					
3,3-Dichlorobenzidine	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Benzo(a)anthracene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Di(2-ethylhexyl)phthalate	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Chrysene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Di-n-octylphthalate	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Benzo(b)fluoranthene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Benzo(k)fluoranthene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Benzo(a)Pyrene (PAH)	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Dibenzo(a,h)anthracene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Indeno(1,2,3-cd)pyrene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Benzo(g,h,i)perylene	ND(2)	ND(2)	ND(2)	ND(0.2)	ug/L
Volatile Organic Compounds (Ref: EPA 524.2)					
Dichlorodifluoromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Chloromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Vinyl Chloride	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Bromomethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Chloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Trichlorofluoromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Trichlorotrifluoroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Methylene Chloride	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,1-Dichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
trans-1,2-Dichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,1-Dichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
2,2-Dichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
cis-1,2-Dichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Chloroform	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Bromochloromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,1,1-Trichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,1-Dichloropropene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Carbon Tetrachloride	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,2-Dichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Trichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,2-Dichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Bromodichloromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Dibromomethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
cis-1,3-Dichloropropene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
trans-1,3-Dichloropropene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,1,2-Trichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,3-Dichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Tetrachloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Chlorodibromomethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Chlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,1,1,2-Tetrachloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Bromoform	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L



Sample Id: S-0000957709

Testing Parameter	Sample	Control	Result	Normalized Result	Units
<b>Chemistry Lab ( Continued )</b>					
1,1,2,2-Tetrachloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,2,3-Trichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,3-Dichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,4-Dichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,2-Dichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Carbon Disulfide	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
Methyl-tert-Butyl Ether (MTBE)	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
tert-Butyl ethyl ether	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Methyl Ethyl Ketone	ND(5)	ND(5)	ND(5)	ND(0.5)	ug/L
Methyl Isobutyl Ketone	ND(5)	ND(5)	ND(5)	ND(0.5)	ug/L
Toluene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Ethyl Benzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
m+p-Xylenes	ND(1)	ND(1)	ND(1)	ND(0.1)	ug/L
o-Xylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Styrene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Isopropylbenzene (Cumene)	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
n-Propylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Bromobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
2-Chlorotoluene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
4-Chlorotoluene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,3,5-Trimethylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
tert-Butylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,2,4-Trimethylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
sec-Butylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
p-Isopropyltoluene (Cymene)	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,2,3-Trimethylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
n-Butylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,2,4-Trichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Hexachlorobutadiene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
1,2,3-Trichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Naphthalene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Benzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Total Trihalomethanes	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L
Total Xylenes	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.05)	ug/L





**Testing Laboratories:**

All work performed at:	<b>Id</b> <hr style="width: 100%; border: 0.5px dashed black;"/> NSF_AA	<b>Address</b> <hr style="width: 100%; border: 0.5px dashed black;"/> NSF International 789 N. Dixboro Road Ann Arbor MI 48105
------------------------	--	---

**References to Testing Procedures:**

<b>NSF Reference</b>	<b>Parameter / Test Description</b>
C2023	BASE/NEUTRAL/ACID EPA METHOD 625 Scan for Tentatively Identified Compounds (TICs)
C2024	Semivolatile Compounds, Base/Neutral/Acid Target 625, Data Workup
C3032	Aluminum in Drinking Water by ICPMS (Ref: EPA 200.8)
C3035	Total Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)
C3038	Barium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3041	Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3043	Bismuth in Drinking Water by ICPMS (Ref: EPA 200.8)
C3046	Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3052	Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3058	Copper in Drinking Water by ICPMS (Ref: EPA 200.8)
C3071	Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)
C3095	Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)
C3100	Lead in Drinking Water by ICPMS (Ref: EPA 200.8)
C3113	Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)
C3115	Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3121	Tin in Drinking Water by ICPMS (Ref: EPA 200.8 )
C3122	Strontium in Drinking Water by ICPMS (Ref: EPA 200.8 )
C3127	Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3135	Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)
C4662	Volatile Organic Compounds (Ref: EPA 524.2)
C6430	Silver in Water by ICPMS (Ref: EPA 200.8)

Test descriptions preceded by an asterisk "\*" indicate that testing has been performed per NSF International requirements but is not within its scope of accreditation.